



Notes:

1. Connect every other joist to supporting member with hurricane straps.
2. Lag bolts connecting ledger to wall shall be located 1 1/2' from top and bottom of ledger. Bolts shall have a 1/4" pre-drilled holes.
3. Use S.Y.P. #2 or higher grade.
4. Concrete shall have a minimum compressive strength of 2500 psi @ 28 days.
5. Reinforcing steel shall have 3" of cover.
6. Soil bearing pressure is assumed to be 1500 psf.

CITY OF HOUSTON	
Department of Public Works and Engineering	
PATIO COVER (ATTACHED)	
APPROVED BY: <i>Ray O'Neil</i>	APPROVED BY: <i>Mark Fisher</i>
BUILDING OFFICIAL	CITY ENGINEER
DATE: 10 / 08 / 09	DWG No.: 08R03-1
1 of 2	