



Notes:

1. A fire resistance rating of half hour shall be permitted in buildings equipped throughout with an automatic fire sprinkler system installed in accordance with NFPA 13.
2. The structural framing supporting the fire-resistance-rated floor/ceiling assemblies shall have an equal or greater fire-resistive rating.
3. Penetrations of wall or floor/ceiling assembly shall be 1 hr fire-rated and shall comply with section R317.3.

CITY OF HOUSTON

Department of Public Works and Engineering

Project: **Two Family Dwelling Horizontal Separation**

Approved by: *Mark Hoeth*
 Building Official

Date: 10 / 28 / 11 Dwg No.: 11-07-R 1 of 1