


- Lumber shall be preservative-treated wood suitable for ground contact and deck construction, SYP #2 or better.
- All cuts shall be field treated with an approved preservative.
- Concrete compressive strength shall be 2500 psi @ 28 days.
- All screws, bolts, washers, nuts and nails shall be hot-dipped zinc-coated galvanized steel.
- For guardrail detail refer to drawing number 08C02



**STANDARD DRAWING**

**CITY OF HOUSTON**  
DEPARTMENT OF PUBLIC  
WORKS & ENGINEERING

**RESIDENTIAL ELEVATED DECK**

1002 WASHINGTON AVE., HOUSTON, TEXAS 77002

APPROVED BY:  
*[Signature]*  
BUILDING OFFICIAL

DATE: 3/21/2017      DWG No: 17-06-R      1 of 1