



**ACKNOWLEDGEMENT OF FIRE EXTINGUISHING SYSTEM**

**INSTRUCTIONS**

Fire suppression systems ***shall be installed*** only by companies and individuals licensed by the State of Texas Fire Marshal's Office. This acknowledgement must be completed by the licensee and submitted via email to the Fire Marshal's Office [hpcfmo@houstontx.gov](mailto:hpcfmo@houstontx.gov) prior to scheduling a final inspection. Please contact 832-394-8853 to schedule the inspection.

**CODE INFORMATION**

**EXCERPT FROM THE 2012 UNIFORM MECHANICAL CODE:**

**513.1 General.** Fire-extinguishing equipment for the protection of grease removal devices, hood exhaust plenums, and exhaust duct systems shall be provided [NFPA 96: 1 0.1.1]

**513.1.1 Protection.** Cooking equipment that produces grease-laden vapors (such as, but not limited to, deep-fat fryers, ranges, griddles, broilers, woks, tilting skillets, and braising pans) and can be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment.

**513.2.2.1 Installation.** Automatic fire-extinguishing systems shall be installed in accordance with the terms of their listing, the manufacturer's installation instructions, and the following standards where applicable:

- (1) NFPA 12
- (2) NFPA 13
- (3) NFPA 17
- (4) NFPA 17A [NFPA 96:10.2.6]
- (5) UL300

Also refer to the following sections in Chapter 5:

**513.2.4.1 Sealing.,**

**513.2.4.2 Obstructions,**

**513.2.6 Water Valve Supervision,**

**513.3 Simultaneous Operation,**

**513.4 Fuel Shutoff**

**513.5 Manual Activation**

**513.6 System Annunciation.**

**EXCERPT FROM 2012 INTERNATIONAL FIRE CODE:**

**904.2.1 Commercial hood and duct systems.** Each required commercial kitchen exhaust hood and duct system required by Section 609 to have a Type I hood shall be protected with an approved automatic fire-extinguishing system installed in accordance with this code.

**904.3.5 Monitoring.** Where a building fire alarm system is installed, automatic fire-extinguishing systems shall be monitored by the building fire alarm system in accordance with NFPA 72.

**ACKNOWLEDGEMENT**

I \_\_\_\_\_ am registered with the State of Texas Fire Marshall's Office,  
*Name*

Registration number \_\_\_\_\_ do hereby certify that the installation of the fire  
*Registration Number*

suppression system(s) located at following address \_\_\_\_\_  
*Project Address*

for project number \_\_\_\_\_ has been installed per the above-mentioned requirements.  
*Project Number*

After installation of the fire suppression system(s) \_\_\_\_\_ has tested the fire  
*Company Name*

system(s) to verify valid operation during a fire event.

\_\_\_\_\_  
**Signature**

**Disclaimer:** This is a legal document any false information given would be considered a violation of the City of Houston Mechanical Code and could be subject to legal action.